

CERTIFICATE OF SAFE DRINKING WATER AND
SANITARY CONDITION

No. 039


Date- 26/04/2025

It is certified that an inspection team sent by DMO, G.B. Nagar visited **DESHRAJ PUBLIC SCHOOL, BISRAKH, SECTOR-1 GREATER NOIDA (WEST), GAUTAM BUDDHA NAGAR**, On 25.04.2025 and found School has safe drinking water facility for students and members of staff & maintaining the hygienic sanitation condition in campus as per the norms prescribed by Central/State/UT govt.

The above valid for the period of 1 year. In case of any rule violation this can be terminated any time.


District Malaria Officer
GautamBudh Nagar

District Malaria Officer
Gautam Budh Nagar


Chief Medical officer
GautamBudh Nagar

मुख्य चिकित्सा अधिकारी
गौतम बुद्ध नगर



Deshraj Public School

Manager



SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida - 201301

Mob. : 9821154906, 8076937396

E-mail. : shriomlab@gmail.com, Web. : www.shriomlab.com, www.shriomlab.in

GSTIN : 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory.

TEST REPORT

ISSUED TO : DESHRAJ PUBLIC SCHOOL
ADDRESS : SEC -1, BISRAKH JALALPUR , GREATER NOIDA
WEST , GAUTAM BUDDHA NAGAR UTTAR PRADESH 203207

REPORT NO : 23042025013
ISSUED DATE : 23.04.2025

(WATER ANALYSIS REPORT)

SAMPLING DETAILS

Sample Description
Sample received on
Sample Collected by
Sampling Quantity
Analysis Duration
Valid Up to

RESULTS

: Potable Water (Ground Water)
: 17.04.2025
: Ravinder Kumar
: 2.0 Ltr
: 18.04.2025 to 23.04.2025
: 22.04.2026

S. No.	Parameters	Units	Limits (as per IS:10500-2012)		Results	Test Methods
			Desirable Limit	Permissible Limit		
1	Color	--	--	--	0.1	IS : 3025(Pt-4) 1983, Reaff. 2017
2	Odour	-	Agreeable	Agreeable	Agreeable	IS : 3025(Pt-5) 1983, Reaff. 2017
3	Taste	-	Agreeable	Agreeable	Agreeable	IS : 3025(Pt-8)-1984, Reaff. 2017
4	Temperature	°C	-	-	23.2	IS: 3025(Pt-9)1984 Reaff 2002
5	pH	-	6.5-8.5	No Relaxation	7.34	IS : 3025(Pt-11)1983, Reaff. 2017
6	Electric Conductivity	µhos/cm	-	-	901	IS : 3025 (Pt-14)-2013
7	Total Hardness (as CaCO ₃)	mg/l	200	600	198.7	IS : 3025(Pt-21)1983, Reaff. 2014
8	Iron (as Fe)	mg/l	0.3	No Relaxation	0.15	APHA 22 nd Ed., 3120B (3111B (AAS),
9	Chlorides (as Cl)	mg/l	250	1000	187.8	IS : 3025(Pt-32)1988, Reaff. 2014
10	Fluoride (as F)	mg/l	1	1.5	< 0.05	APHA 22 nd Ed., 4500F(D)
11	TDS	mg/l	500	2000	540.6	IS: 3025(Pt-16)1984, Reaff. 2017
12	Calcium (as Ca ²⁺)	mg/l	75	200	36.8	IS :3025(Pt-40)1991, Reaff. 2014
13	Magnesium (as Mg ²⁺)	mg/l	30	100	26.1	APHA 22 nd Ed., 3500-Mg (B)
14	Sulphate (as SO ₄)	mg/l	200	400	24.5	IS : 3025(Pt-24)1986, Reaff. 2014
15	Nitrate(as NO ₃)	mg/l	45	No Relaxation	22.8	IS : 3025(Pt-34)1988, Reaff. 2014
16	Alkalinity (as CaCO ₃)	mg/l	200	600	198.8	IS: 3025(Pt-23)1986, Reaff. 2014
Bacteriological Parameters						
1	Total Coli form	MPN/100ml	Shall Not Be Detectable	Not Detected (<2)	IS : 1622-1981 (Reaff.2003)	
2	<u>E.coli</u>	<u>E.coli</u> /100ml	Shall Not Be Detectable	Absent	IS : 1622-1981 (Reaff-2003)	

Remark :- The Sample Confirms as per IS 10500-2012 Specification for above test only

End of Report Page(01 of 01)



Deshraj Public School

Manager

Shri Om Testing & Research Laboratory

Ravinder Kumar Sharma

R Sharma
23/04/25
Technical Manager

Authorised Signatory

(Name, Designation & Signature with Seal)

STR/LAB/QF/058

Rev:00

Note: 1. The results indicated only refer to the tested samples and listed parameters and do not endorse any product. The customer asked for the above tests only.

2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.

3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of the laboratory.

4. The samples received shall be destroyed after 30 days from the date of issue of the certificate unless specified otherwise and sample for biological testing will be destroyed after 7 days of testing.



SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida - 201301

Mob. : 9821154906, 8076937396

E-mail. : shriomlab@gmail.com, Web. : www.shriomlab.com, www.shriomlab.in

GSTIN : 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory.

TEST REPORT

ISSUED TO : DESHRAJ PUBLIC SCHOOL
ADDRESS : SEC -1, BISRAKH JALALPUR , GREATER NOIDA
WEST , GAUTAM BUDDHA NAGAR UTTAR PRADESH 203207

REPORT NO : 23042025012
ISSUED DATE : 23.04.2025

(WATER ANALYSIS REPORT)

SAMPLING DETAILS

Sample Description
Sample received on
Sample Collected by
Sampling Quantity
Analysis Duration
Valid Up to

RESULTS

: Drinking Water (RO Water)
: 17.04.2025
: Ravinder Kumar
: 2.0 Ltr
: 18.04.2025 to 23.04.2025
: 22.04.2026

S. No.	Parameters	Units	Limits (as per IS:10500-2012)		Results	Test Methods
			Desirable Limit	Permissible Limit		
1	Color	--	--	--	0.1	IS : 3025(Pt-4) 1983, Reaff. 2017
2	Odour	-	Agreeable	Agreeable	Agreeable	IS : 3025(Pt-5) 1983, Reaff. 2017
3	Taste	-	Agreeable	Agreeable	Agreeable	IS : 3025(Pt-8)-1984, Reaff. 2017
4	Temperature	°C	-	-	18.7	IS: 3025(Pt-9)1984 Reaff 2002
5	pH	-	6.5-8.5	No Relaxation	7.11	IS : 3025(Pt-11)1983, Reaff. 2017
6	Electric Conductivity	µhos/cm	-	-	465	IS : 3025 (Pt-14)-2013
7	Total Hardness (as CaCO ₃)	mg/l	200	600	44.4	IS : 3025(Pt-21)1983, Reaff. 2014
8	Iron (as Fe)	mg/l	0.3	No Relaxation	0.10	APHA 22 nd Ed., 3120B (3111B (AAS),
9	Chlorides (as Cl)	mg/l	250	1000	43.2	IS : 3025(Pt-32)1988, Reaff. 2014
10	Fluoride (as F)	mg/l	1	1.5	0.01	APHA 22 nd Ed., 4500F(D)
11	TDS	mg/l	500	2000	88.6	IS: 3025(Pt-16)1984, Reaff. 2017
12	Calcium (as Ca ²⁺)	mg/l	75	200	12.8	IS :3025(Pt-40)1991, Reaff. 2014
13	Magnesium (as Mg ²⁺)	mg/l	30	100	3.03	APHA 22 nd Ed., 3500-Mg (B)
14	Sulphate (as SO ₄)	mg/l	200	400	33.8	IS : 3025(Pt-24)1986, Reaff. 2014
15	Nitrate(as NO ₃)	mg/l	45	No Relaxation	17.8	IS : 3025(Pt-34)1988, Reaff. 2014
16	Alkalinity (as CaCO ₃)	mg/l	200	600	58.2	IS: 3025(Pt-23)1986, Reaff. 2014
Bacteriological Parameters						
1	Total Coli form	MPN/100ml	Shall Not Be Detectable	Not Detected (<2)	IS : 1622-1981 (Reaff.2003)	
2	<u>E.coli</u>	<u>E.coli</u> /100ml	Shall Not Be Detectable	Absent	IS : 1622-1981 (Reaff-2003)	

Remark :- The Sample Confirms as per IS 10500-2012 Specification for above test only

****End of Report** Page(01 of 01)**



Deshraj Public School
Manager

Shri Om Testing & Research Laboratory
Ravinder Kumar Sharma

R Sharma
93/4/25
Technical Manager

Authorised Signatory
(Name, Designation & Signature with Seal)